

PORSE 11, 3, 18.1 V4



NPDES #1300 Oily Discharge General Permit
Discharge Monitoring Report

Submit report monthly by 15th of following month to:
 Oregon DEQ
 2020 SW 4th Avenue, Suite 400
 Portland, Oregon 97201

Legal Name: KINDER MORGAN LIQUID TERMINALS LLC

Site/File ID #: 32300

Common Name: LINNTON TERMINAL

County: MULTNOMAH

Facility Location: 11400 NW ST HELENS RD , PORTLAND

Month/Year Sept. 2006

Monitoring for Oil/Water Separator

TANK 3034

| Day | Oil and Grease (mg/L) Frequency varies, see permit | Visible Sheen Daily, visual observation | Ethanol and/or MBTE Quarterly grab sample, if present on site and in bulk | Flow Daily estimate, when discharging |
|---------|---|--|--|--|
| Limit | 10 mg/L monthly, 15 mg/L daily max. | No visible sheen at any time | No limit | No limit |
| 1 | | | | |
| 2 | | | | |
| 3 | | | | |
| 4 | | | | |
| 5 | | | | |
| 6 | | | | |
| 7 | | | | |
| 8 | | | | |
| 9 | | | | |
| 10 | | | | |
| 11 | | | | |
| 12 | | | | |
| 13 | | | | |
| 14 | | | | |
| 15 | | | | |
| 16 | | | | |
| 17 | | | | |
| 18 | | | | |
| 19 | | | | |
| 20 | | | | |
| 21 | | | | |
| 22 | | | | |
| 23 | | | | |
| 24 | | | | |
| 25 | | | | |
| 26 | | | | |
| 27 | | | | |
| 28 | | | | |
| 29 | | | | |
| 30 | | | | |
| 31 | | | | |
| Total | | | | |
| Max. | | | | |
| Average | | | | |

NO DISCHARGE

See Reverse Side for Additional Monitoring and Signature Block

Stormwater Monitoring

Only for facilities required to have NPDES permits for stormwater, per 40 CFR 122.26
Monitoring required for each point identified in the Stormwater Pollution Control Plan

| Day | Visible Sheen | Floating Solids (associated with industry) | Total Copper (mg/L) | Total Lead (mg/L) | Total Zinc (mg/L) | pH (S.U.) | Total Suspended Solids (mg/L) |
|----------------|--|--|-----------------------------------|-----------------------------------|-----------------------------------|-----------------------------------|-------------------------------------|
| | Daily when discharging, visual observation | Once per month when discharging | Twice per year, grab sample | Twice per year, grab sample | Twice per year, grab sample | Twice per year, grab sample | Twice per year, grab sample |
| Limit | No visible sheen | No visible discharge* | 0.1 mg/L* | 0.4 mg/L* | 0.6 mg/L* | Within 6.0 to 9.0 | 130 mg/L* |
| 1 | | | | | | | |
| 2 | | | | | | | |
| 3 | | | | | | | |
| 4 | | | | | | | |
| 5 | | | | | | | |
| 6 | | | | | | | |
| 7 | | | | | | | |
| 8 | | | | | | | |
| 9 | | | | | | | |
| 10 | | | | | | | |
| 11 | | | | | | | |
| 12 | | | | | | | |
| 13 | | | | | | | |
| 14 | | | | | | | |
| 15 | | | | | | | |
| 16 | | | | | | | |
| 17 | | | | | | | |
| 18 | | | | | | | |
| 19 | | | | | | | |
| 20 | | | | | | | |
| 21 | | | | | | | |
| 22 | | | | | | | |
| 23 | | | | | | | |
| 24 | | | | | | | |
| 25 | | | | | | | |
| 26 | | | | | | | |
| 27 | | | | | | | |
| 28 | | | | | | | |
| 29 | | | | | | | |
| 30 | | | | | | | |
| 31 | | | | | | | |
| Total | | | | | | | |
| Max. | | | | | | | |
| Average | | | | | | | |

*These are benchmarks, not effluent limits. If benchmarks are exceeded, review/possible revision of Stormwater plan is required. See permit for more details.

Signature Requirement

I certify, under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

Signature of Responsible Official: _____

Name and Title (Please Print): _____

Date of Signature: _____

Telephone: _____

Steve Turpate
Steve Turpate Field Scheduler
10-2-06 503 220 1276